



NOTES

TIMBER TREATMENT

- SAWN TIMBER IN CONTACT WITH THE GROUND TO BE H5.
- TREATMENT SHALL COMPLY WITH THE CURRENT REQUIREMENTS OF THE TIMBER PRESERVATION COUNCIL.
- ALL TIMBER SHALL BE BRANDED WITH THE APPROPRIATE WOODMARK.
- IT IS PREFERRED THAT TIMBERS BE TREATED AT LEAST 2 MONTHS PRIOR TO USE.

FIXINGS

- GENERAL STRUCTURAL USE 125mm x 4mm FH NAILS.
- ALL NAILS SHALL BE HOT DIPPED GALVANISED.
- ALL STEELWORK INCLUDING FIXINGS TO BE 316 STAINLESS STEEL WITHIN A COASTAL ENVIRONMENT. FIXINGS TO USE NON FERROUS WASHERS (E.G. NYLON) TO PREVENT ELECTROLYSIS.

CULVERT PIPE

- IN FLOWING STREAMS, PIPE SHOULD BE SET AT STREAM BED LEVEL AT BOTH ENDS TO ENABLE FISH PASSAGE.

CONCRETE

- ALL CONCRETE TO HAVE MINIMUM STRENGTH OF 20MPa.

TYPICAL USES

- PATHS CROSSING POORLY DRAINED OR FLOOD PRONE AREAS

