

Feedback Form

Stormwater Management Devices in the Auckland Region Guideline Document 2017/001



The *Stormwater management devices in the Auckland Region* Guideline Document, known as GD2017/001, is intended for a wide audience associated with land development and land-use planning where stormwater management is of consideration. The production of this document has included numerous reviews and the collation of feedback from within Auckland Council. However we value your feedback for its continued improvement. If you have any specific comments regarding this guideline document, please use this form to record it and email to wsd@aucklandcouncil.govt.nz

We would appreciate feedback to be supplied by providing specific comments in the same format as the example response below (i.e. alternative passages of text are preferred over generalised statements). Your suggested improvements will be collated and reviewed. Reviews of this guideline document will be undertaken periodically or on an urgent basis if deemed necessary.

Please ensure that your details are provided with this form so that we can contact you to discuss your suggestion/s.

Name:		Organisation:		Phone:		Email:	
--------------	--	----------------------	--	---------------	--	---------------	--

Please state your role or interest in stormwater management:

resident / developer / community group member / consultant / contractor / government staff / other (please state):

Section Reference	Section Title	Comment	Suggested Alternative Text	Justification for this Amendment
C2.2.1	<i>Table 42: Pervious paving design considerations and specifications</i>	<i>Plastic void formers must be checked to ensure they are fit for the proposed use</i>	<i>If plastic void formers are used, loading and cover requirements must be checked to ensure they are fit for proposed use</i>	<i>The structural requirements for the plastic void formers are different to the usual drainage scoria and this shall not be overlooked during the device design</i>